

# EC Type Examination Certificate

This is to certify that:

Telesto Sp. z o.o.  
Ul. Fabryczna 5  
26-130 Suchedniow  
Poland

Holds Certificate Number:

CE 630332

In respect of:

## **Fire Extinguisher Assemblies (Portable and Mobile)**

On the basis of our examination under the requirements of Council Directive 97/23/EC Module B of the Pressure Equipment Directive, as transposed into UK law by the Pressure Equipment Regulations SI 1999 2001.

For and on behalf of BSI, a Notified  
Body for the above Directive  
(Notified Body Number 0086):



Gary Fenton, Global Product Certification Director

First Issued: 29/10/2015

Latest Issue: 29/10/2015

Expiry Date: 28/10/2025

Page: 1 of 2

...making excellence a habit.™

# EC Type Examination Certificate

No. CE 630332

## Additional Information

### Limitations of Certificate Validity

Products: Portable LP Fire extinguisher assemblies in the following models:

Water Mist – EX-WM1, EX-WM2, EX-WM3, EX-WM6, EX-WM9

Green Foam Mist – EX-GFM2 and EX-GFM6

PS = 20.0 bar g

TS = +5°C to +60°C

Products: Portable LP Fire extinguisher assemblies in the following models:

Water Mist (St/St Body) – EX-WM6S and EX-WM9S

PS = 18.0 bar g

TS = +5°C to +60°C

Products: Portable LP Fire extinguisher assemblies in the following models:

Ecopac Foam Mist – EP-FM6S (excluding any BA assembly) and EP-FM13S

Ecopac Water Mist - EP-WM13S

PS = 18.0 bar g

TS = +5°C to +60°C

Products: Mobile LP Fire extinguisher assemblies in the following models:

Water Mist – TR-WM25S, TR-WM50S, TR-WM100S

Foam – TR-F25S, TR-F50S, TR-F100S

Foam Mist – TR-FM25S, TR-FM50S, TR-FM100S

Green Foam Mist – TR-GFM25S, TR-GFM50S, TR-GFM100S

PS = 20.0 bar g

TS = +5°C to +60°C

All as described in Technical File No. TFS/PED/1, Rev. 0.

First Issued: 29/10/2015

Latest Issue: 29/10/2015

Expiry Date: 28/10/2025

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 845 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.