

## Certificate of Product Approval

Certificate Number: 1129a

Issue: 03

### Telesto Sp. z o.o.

Ul. Fabryczna 5,  
26-130 Suchedniow,  
Poland

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Products

'SafetyChef' Restaurant Fire  
Suppression System

#### Standards

**LPS 1223: Issue 2.3**

Requirements and Testing Procedures for the LPCB  
Certification and Listing of Fixed Fire Extinguishing  
Systems for Catering Equipment.

This certificate and appendix is maintained and held in force through regular surveillance activities

*S.A.C. Colwell*

Signed for LPCB

Sarah Colwell  
Verifier

05 June 2015  
Date of Issue

05 August 2013  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



**bre**

## Appendix to Certificate No: 1129a Telesto Sp. z o.o.

Issue: 03

### 'SafetyChef' Restaurant Fire Suppression System to LPS1223:2.3

Product name	Designation	Description	LPCB Ref. No.
SafetyChef	320 cm	Manual and Automatic operation, water mist restaurant suppression system up to 320 cm protected length supplied from single or manifold containers, 12.27, 30 and 50 litre volumes.	1129a/01
SafetyChef	800 cm	Manual and Automatic operation, water mist restaurant suppression system up to 800 cm protected length supplied from single or manifold containers, 12.27, 30 and 50 litre volumes.	1129a/02

**Note:**

- "SafetyChef" restaurant water mist suppression systems shall be installed, maintained and operated in accordance with Telesto Sp. z o.o SafetyChef fire extinguishing mist system installation, operation and maintenance manual No. SGMP-K/IMS/5 Rev. 5 dated 22.05.2015, and Telesto SafetyChef system technical specification No. SGMP-K/DTI/6 Rev 6 dated 22.05.2015.
- For use only with Fusible link, glass bulb and pneumatic detection systems as detailed in Telesto SafetyChef system technical specification No. SGMP-K/DTI/6 Rev 6 dated 22.05.2015.

This certificate and appendix is maintained and held in force through regular surveillance activities

*S.A.C. Colwell*

Signed for LPCB

Sarah Colwell  
Verifier

05 June 2015  
Date of Issue

05 August 2013  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR Tag or contact us.

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [Enquiries@breglobal.com](mailto:Enquiries@breglobal.com)



**bre**