

BRE Global Test Report

Fire tests to Annex C of BS 8458 with a Telesto low pressure water mist system incorporating DGWP-62 nozzles

Prepared for: Telesto Sp. Z o.o.
Date: 18 July 2016
Report Number: P102532-1000 Issue: 2

BRE Global Ltd
Watford, Herts
WD25 9XX

Customer Services 0333 321 8811

From outside the UK:
T + 44 (0) 1923 664000
F + 44 (0) 1923 664010
E enquiries@bre.co.uk
www.bre.co.uk

Prepared for:
Telesto Sp. Z o.o.
Ludwinowska 17,
02-856 Warszawa
Poland



4 Conclusion

The Telesto water mist system submitted to BRE Global for testing and as described in section 2.3 of this report met the recommendations of Clause 6.1 of BS 8458: 2015 when tested in accordance with Annex C, Clauses C.1 to C.4.