

Certificate of Product Approval

Certificate Number: 1129a

Issue: 03

Telesto Sp. z o.o.

Ul. Fabryczna 5,
26-130 Suchedniów,
Poland

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Products

'SafetyChef' Restaurant Fire
Suppression System

Standards

LPS 1223: Issue 2.3

Requirements and Testing Procedures for the LPCB
Certification and Listing of Fixed Fire Extinguishing
Systems for Catering Equipment.

This certificate and appendix is maintained and held in force through regular surveillance activities

S. A. Colwell

Signed for LPCB

Sarah Colwell

Verifier

05 June 2015

Date of Issue

05 August 2013

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 1129a Telesto Sp. z o.o.

Issue: 03

'SafetyChef' Restaurant Fire Suppression System to LPS1223:2.3

Product name	Designation	Description	LPCB Ref. No.
SafetyChef	320 cm	Manual and Automatic operation, water mist restaurant suppression system up to 320 cm protected length supplied from single or manifold containers, 12.27, 30 and 50 litre volumes.	1129a/01
SafetyChef	800 cm	Manual and Automatic operation, water mist restaurant suppression system up to 800 cm protected length supplied from single or manifold containers, 12.27, 30 and 50 litre volumes.	1129a/02

Note:

- "SafetyChef" restaurant water mist suppression systems shall be installed, maintained and operated in accordance with Telesto Sp. z o.o SafetyChef fire extinguishing mist system installation, operation and maintenance manual No. SGMP-K/IMS/5 Rev. 5 dated 22.05.2015, and Telesto SafetyChef system technical specification No. SGMP-K/DTV/6 Rev 6 dated 22.05.2015.
- For use only with Fusible link, glass bulb and pneumatic detection systems as detailed in Telesto SafetyChef system technical specification No. SGMP-K/DTV/6 Rev 6 dated 22.05.2015.

This certificate and appendix is maintained and held in force through regular surveillance activities

S. A. Colwell

Signed for LPCB

Sarah Colwell
Verifier

05 June 2015
Date of Issue

05 August 2013
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).
To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR Tag or contact us.
LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: Enquiries@breglobal.com



bre